

Wyoming Valley Sanitary Authority
Exeter's Monthly Report
6/01/2019 To 6/30/2019

- 6-03-19 Flushed (1) storm line. Tried to camera, no luck.
Note: Line filled with debris
Summary: (4) men plus support vehicles (8) hrs.
Street worked on: Cedar St
- 6-04-19 Flushed (1) storm line.
Note: Line filled with large debris. Must be a large brake in the line.
Marked location and suggested a dig to find problem.
Summary: (4) men plus support vehicles (4.5) hrs.
Street worked on: Cedar St
- 6-11-19 Flushed (2) problem lines
Summary: (4) men plus support vehicles (1) hr.
Street worked on: Slocum Ave
- 6-13-19 Checked problem lines
Summary: (2) men plus support vehicles (3) hrs.
- 6-24-19 Flushed (12) problem lines
Summary: (3) men plus support vehicles (4) hrs.
Streets worked on: Grant - Warsaw - Park Ln - Orchard & Barber St.
- 6-25-19 Cleaned (1) catch basin
Summary: (4) men plus support vehicles (1) hr.
- 6-26-19 Flushed (11) problem lines with chemical degreaser
Flushed chemical degreaser into Pump Stations #1E, Bryd St
#2E, Cedar St & #5E, Wilson St
Summary: (4) men plus support vehicles (8) hrs.
Streets worked on: Stevens Ln – Barber – Schooley Ave & Rt. 92

Summary of worked performed in June 2019

1. Flushed (25) sewer lines
2. Flushed (1) storm line
3. Cleaned (1) catch basins

Ross Giamusso W.V.S.A.
Collection Department (Foreman)

CC: Debbie Serbin